



Address:
Rotthausen Str. 21, DE 45879 Gelsenkirchen

Switchboard +49 (0)209 9242-0
Telefax +49 (0)209 9242-222
Internet www.hyg.de

Our reference: W-362868e-22-Zd
Contact person: B. Zeidler

Gelsenkirchen, 05.09.2022

Test - certificate

hygiene-conformity check to the design requirements of
selected regulations

Test institute: Hygiene Institut des Ruhrgebiets
Institut für Umwelthygiene und Toxikologie
Rotthausen Straße 21
45879 Gelsenkirchen

Test object: Plate heat exchanger of the type
RFC+ and RFK+

Manufacturer: RECUTECH s.r.o.
Poděbradská 289
530 09 Pardubice
Czech Republic



Basis of the examination: ✓ VDI 6022, sheet 1 (01/2018) ✓ DIN 1946, part 4 (09/2018)
✓ VDI 3803, sheet 1 (05/2020) ✓ ÖNORM H 6020 (06/2019)
✓ ÖNORM H 6021 (08/2016) ✓ SWKI VA104-01 (01/2019)
✓ SWKI VA105-01 (08/2015)

Validity period: 5 years 09/2022 – 09/2027

Test report: W-362868-22-Zd

In conclusion it can be stated that the examined Plate heat exchanger of the type RFC+ and RFK+, as specified in the test report W-362868-22-Zd, is in compliance with the above mentioned regulations.

(B. Zeidler)
clerk of the Department hygienic building technology

(J. Rolle B. Eng.)
clerk of the Department hygienic building technology

issued 05.09.2022, Gelsenkirchen

Within the framework of the conformity check the hygiene-relevant requirements of the above mentioned regulations were examined. Requirements of other regulations that refer to the above mentioned regulations were not part of the examination. Additionally, the conformity check does not include a toxicological or sensory testing of the introduced materials.